WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 6703
Rec. Aug 28 1962
Well No.
Permit No.
Do not fill in

Owner: Vinnell Corporation
Driller: C.C.Davidson
Address: Box 147 Elko Nevada
Address: Box 69 Fallon Nevada Lic. No. 337
Elko

Location of well: 1/4 N.W. 1/4 Sec. 2, T. 35 N/S, R. 57 E, in County

or 17 miles east of Elko Nev. on U.S.highway 40 ½ mi.north.
impossiable to get correct location.

Water will be used for: Watering road construction
Total depth of well: 352'

Size of drilled hole: 12"
Weight of casing per linear foot: 25

Thickness of casing: 3/16
Temp. of water: nil

Diameter and length of casing: 12¼ I.D. 352
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 96'

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: 8-7-1962
Date of completion of well: 8-11-1962

Type of well rig: Cable tool

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3	3	top soil
3	112	109	clay & gravel
112	115	3	water sand small amount
115	210	95	blue and yellow clay small amount gravel cemented
210	218	8	cemented gravel and water sand.
218	310	92	cemented gravel blue clay.
310	352	32	lava gravel and sand.

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 112 to 115 ft.
210 218

Other aquifers
310 352

First water at 112 feet.

Casing perforated
from 140 to 160 ft.
210 212
310 350

Size of perforations
½ x 4 8 rows per ft.

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
12¾	0	352	352	solid pipe to 140' drive shoe used 1'x 12" 3/16 in wall plate

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

pumped from 240' app.225 G.P.M. very poor well.

I believe this well would produce a greater amount of water had it been properly test pumped.

this water never tested but appears to be good drinking water.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed C.E.Davidson
Well Driller

By C.E. Davidson

License No. 5924

Dated 8-28-1962, 19 62

(Not to be filled in by Driller)