Carson.

Recorded copy

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 6802
Rec. Oct. 22 1962
Well No.
Permit No.
Do not fill in

Owner: Robert C. Foremaster — Driller: Patrick H. Thompson

Address: Hiko, Nevada — Address: 217 So. 26th St. L.V.N. Lic. No. 192

Location of well: NW ¼ SE¼ Sec. 11, T. 5 N/S, R. 60 E, in Lincoln County

or E½, NW¼, NW¼, SE¼ of above Section

Water will be used for: Commercial (Ser. Sta.) — Total depth of well: 127'

Size of drilled hole: 10" — Weight of casing per linear foot: 13#

Thickness of casing: 10 gauge — Temp. of water: Cold

Diameter and length of casing: 8" O.D. Dia. -- 128' length
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 82'

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: Dec. 22, 1961 — Date of completion of well: Dec. 27, 1961

Type of well rig: Cable tools

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	28	28	Sand & gravel
28	85	57	Cemented gravel
85	127	42	Cemented sand & gravel (water bearing)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 85 to 127 ft.

Other aquifers:

First water at 85 feet.

Casing perforated
from 77 to 127 ft.

Size of perforations
3/16" x 12" - 4 rows

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8-5/8"	+ 1	127	128	no grout

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bail Test 30 G.P.M. from 110 ft.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Patrick H. Thompson
Well Driller

By

License No. 192

Dated Oct. 16, 19 62

(Not to be filled in by Driller)

Sent for Appl 1-7-63

1962 OCT 22 AM 11 14
STATE ENGINEER
OFFICE