

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 6812
 Rec. Oct 22 1962
 Well No. _____
 Permit No. 27095
Do not fill in

Owner Dr. Winthrop G. Dale Driller E. R. Baxter
 Address P.O. Box 1047 Carson City Address Box 1026 Carson City Lic. No. 322
 Location of well: SE 1/4 SE 1/4 Sec. 6, T. 15 N., R. 20 E. in Owensby County
 or _____
 Water will be used for Home Use Total depth of well 137'
 Size of drilled hole 7 7/8" Weight of casing per linear foot 9.5
 Thickness of casing 10 Ga. Temp. of water Normal
 Diameter and length of casing 6" ID 120' in length
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)
 If flowing well give flow in c.f.s. or g.p.m. and pressure _____
 If nonflowing well give depth of standing water from surface 15'
 If flowing well describe control works _____
(Type and size of valve, etc.)
 Date of commencement of well 24 Aug. 62 Date of completion of well 25 Aug. 62
 Type of well rig Pantadrill (1500) Rotary

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	19	19	Sand
19	26	7	Coarse Sand
26	92	67	Fine Sand
92	119	27	Coarse Sand
119	137	18	Fine Sand

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 92 to 119 ft.

Other aquifers _____

First water at 42 feet.

Casing perforated from 90 to 120 ft.

Size of perforations

3/16



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6"10	0	120	120	7 7/8" Hole drilled to 130' with 120' of 6"10 casing set. Hole cemented at surface.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed J. R. Baxter
Well Driller

By.....

License No. 322

Dated Aug. 26, 1962

(Not to be filled in by Driller)

1962 OCT 22 AM 11-00

STATE ENGINEER