WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 7255
Rec. July 21, 1963
Well No.
Permit No. 20979
Do not fill in

Owner: K. & K. Distrubition Company Driller: Effinger Drilling & Pump Servic
Address: 3853 South Highland Drive Address: Box 579 City Lic. No. 21

Location of well: NW ¼ SW ¼ Sec. 17, T. 21 N/S, R. 61 E, in Clark Count
or 3853 South Highland Drive

Water will be used for: Quasi-Municipal Total depth of well: 300 feet

Size of drilled hole: 14 inch Weight of casing per linear foot:

Thickness of casing: 3/16 Temp. of water:

Diameter and length of casing: 10" ID 300 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 57'

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: June 3, 1963 Date of completion of well: June 15, 1963

Type of well rig: "72 Speedstar"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3	3	Sandy Clay
3	5	2	Calichie
5	12	7	Clay
12	20	8	Limestone
20	28	8	White Clay
28	35	7	Brown Clay
35	47	12	Limestone
47	65	18	Brown Clay
65	75	10	White Sandstone
75	95	20	Brown Clay
95	110	15	Sand (Water)
110	140	30	White Clay
140	165	25	Limestone (Water)
165	180	15	White Clay
180	190	10	Gravel (Water)
190	220	30	Red Clay
220	300	80	Gravel (Water)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 220 to 300 ft.

Other aquifers: 180-190
140-165

First water at 95 feet.

Casing perforated
from 200 to 295 ft.

Size of perforations
1/8" X 12" Torch

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CA ECORD

Diam. casing	From feet	t	Length	"Remarks"—Seals, Grouting, Etc.
10ID	0	300	300	Cemented from 0 to 50 feet 2 yards of cement Graveled packed from 50 to 295 feet 8 yards of pea gravel

GENERAL INFOR ON—Pumping Test, Quality of Water, Etc.

3HP Berkeley Sub 210' 1¼" Riser, 210' #14 cable 525 ASME tank.
Model #4DM19 3phase 230v.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drill & Pump
Well Driller

By D Effinger

License No. 212

Dated June 23, 1963

(Not to be filled in by Driller)