Log No 8631
Rec.
Well No.
Permit No. 22362
Do no. [illegible]

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner Fitzgerald Driller [illegible]

Address [illegible] Ferguson St., N. L. V. Address [illegible] Lic. No. [illegible]

Location of well: [illegible] ¼SE ¼ Sec. 14, T. 20 N/S, R 61 E, in Clark County

or

Water will be used for Domestic Use Total depth of well 300'

Size of drilled hole 12" to 50', 10" to 300' Weight of casing per linear foot [illegible]

Thickness of casing 10 gauge Temp. of water

Diameter and length of casing 8" D. from [illegible]' to 300'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 60'

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well 12-30-64 Date of completion of well 1-15-65

Type of well rig [illegible]

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	5	5	top soil
5	30	25	brown clay
30	35	5	caliche
35	60	25	gravel & clay streaks
60	85	25	brown clay
85	105	20	brown clay & gravel streaks
105	170	65	brown clay & gravel streaks (water)
170	200	30	brown clay & gravel streaks
200	225	25	gravel (water)
225	235	10	clay
235	247	12	grey sandy clay & gravel streaks
247	265	18	grey sticky clay & gravel streaks.
265	300	35	grey gritty clay & gravel streaks. (water)

Water-bearing Formation, Casing Perforations, etc.

Chief aquifer (water-bearing formation)

from [illegible] to [illegible]

Other aquifers 2[illegible] to 225'

[illegible] 15 to 170'

First water at 15' feet

Casing perforated

from 60 to 160 ft.

Size of perf. [illegible]/16" [illegible] 20

(over)

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
6"ID	0	300	300'	Graveled well with 11 tons of gravel. Cemented casing in place with 2½ yards of well grout to 50'.

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

Bailtested well at 70GPM AT 100'

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed S.R. McKinney & Sons, Inc.
Well Driller

By J.L. McKinney

License No. 45

Dated 8-9, 1965

(Not to be filled in by Driller)