Log No. 8793
Rec. Jan 3 1966
Well No.
Permit No. 20846 - 23623
Do not fill in.

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner Roy T. Gibson Driller Wm B. Gibson

Address 1099 Waterford Dr. Dallas Tex Address Nyala Via Tonopah Lic. No. New

Location of well: NW¼ SW¼ Sec. 27, T. 5 N/S, R. 55 E, in Nye County

Permit No. 20846

Water will be used for Irrigation & Domestic Total depth of well 245'

Size of drilled hole 28" Weight of casing per linear foot 60 lb

Thickness of casing 1/4" Temp. of water 60°F

Diameter and length of casing 18" X 245'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure not

If nonflowing well give depth of standing water from surface 31 ft

If flowing well describe control works not
(Type and size of valve, etc.)

Date of commencement of well 5-10-1965 Date of completion of well 5-14-1965

Type of well rig Winter Weiss Reverse Circulating Rotary

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	13	13	Sandy Loam Topsoil
13	15	~~[illegible]~~ 15	Clay Sand & Gravel
15	16	1	Sand & Gravel (Cemented)
16	28	12	Clay
28	35	7	Sand & Gravel
35	37	2	Sandstone
37	62	24	Sand & Gravel (Loose)
62	65	2	Clay & Gravel
65	75	10	Sand & Gravel (Coarse Loose)
75	80	5	Clay, White
80	85	5	Sand & Gravel
85	94	9	Clay
94	98	4	Sand & Gravel
98	113	15	Clay
113	123	10	Sand & Gravel (Very Loose)
123	127	~~[illegible]~~ 5	Clay
127	131	4	Sand & Gravel
131	144	13	Clay
144	150	6	Sand & Gravel
150	154	4	Clay
154	157	3	Sand & Gravel
157	193	36	Clay
193	200	7	Gravel
200	221	21	Clay
221	234	13	Sand & Gravel (Coarse Loose)
234	245	11	Clay

(OVER)

Water-bearing Formation, Casing Perforations, etc.

Chief aquifer (water-bearing formation)

from 193 to 200 ft.

Other aquifers 65-75, 80-85, 94-98, 127-131, 144-150, 154-157, 193-200, 221-234

First water at 31 feet.

Casing perforated

from 70' to 245 ft.

Size of perforations

1/4" X 6"

919

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
18"	0	245'	245'	

GENERAL INFORMATION—Pumping Test, or Boiling Test, Quality of Water, etc.

Small Test Pump Used in This Well
Test Ran for 14 hrs - Recovery was 2500 gal/min
There was no variation in Drawdown
after water Cleared -

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed W. M. B. Gibson
Well Driller

By.....

License No.....

Dated Nov 16, 1965

OFFICE
STATE ENGINEER
1965 JAN 3 AM 11 23

(Not to be filled in by Driller)