Log No. 8904
Rec. Mar. 21, 1966
Well No.
Permit No.
Do not fill in.

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner: Medalion Mobile Estates Driller: M. C. Nichols

Address: Reno % Wes. Newman Address: 425 Richards Way Sparks Lic. No. 414

Location of well: ¼ ¼ Sec. 10, T. 20 N/S, R. 19 E, in Washoe County

or Golden Valley – Medalion Mobile Estates Subdivision.

Water will be used for: Domestic use Total depth of well: 200

Size of drilled hole: 24 inch Weight of casing per linear foot:

Thickness of casing: 1/4 inch Temp. of water:

Diameter and length of casing: 14 inch 180 FT.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 60 FT.

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: 2/17/66 Date of completion of well: 3/15/66

Type of well rig: ROTARY

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	15		TOPSOIL
15	55		CLAY INTO DECOMP. GRANIT
55	65		Light GRAVel + Rock
65	70		CLAY + DECOMP. GRANIT
70	80		CLAY + D. G.
80	100		HEAVY GRAVel – Rocky
100	120		Mixed D. G. + Rocky
120	140		Rocky – D. G.
140	160		Yellow CLAY.
160	175		SAND – CLAY + GRANIT SAND.
175	180		GRAVel – HEAVY – Rocky
180	200		DECOMP. GRANIT + CLAY.

Water-bearing Formation, Casing Perforations, etc.

Chief aquifer (water-bearing formation)

from 80 to 140 ft.

Other aquifers: 160 – 180

THE WATER IS IN THE ROCKY FORMATIONS MORE THAN THE SAND + GRAVel.

First water at 55 feet.

Casing perforated

from 60 to 180 ft.

Size of perforations

1/8" X 6" VERTICAL

(OVER)

919

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
14"	0	180	180	The 24" Hole was stopped at 180 ft. 12" was drilled to 200. The casing was stopped & Benched at 180. The anular space was gravel packed to 50 ft. + cemented with Ready Mix cement to the surface.

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

No pump test as yet.
Bailing test with 100 gal. bailer app. 1 per minute after 1 hour pulled the water down to 80 ft. + held. Clarity of water Good, No sand. Fast Recovery back to 60 ft.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Melvin C. Nichols
Well Driller

By Enloe Drilling Co.

License No. 414

Dated 3/12/, 1966

(Not to be filled in by Driller)

1966 MAR 21 AM 11 59
OFFICE
STATE ENGINEER