LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material
553	620	67	Cemented gravel w/stks red clay
620	789	169	Cemented gravel
789	1000	211	Cemented gravel w/stks red clay 6" to 12" thick

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
16"	plus1.5	588	589.5	16" grouted to 55'
12"	578	1000	422	

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

Test pumped 1100 GPM from 249'

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Patrick V. Thompson
Well Driller

By.....

License No. 192

Dated February 24, 66, 19.....

(Not to be filled in by Driller)

RECEIVED
MAR 24 1966
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA