Log No. 9129
Rec. Aug 19 1966
Well No.
Permit No.
009 Do not fill in.

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner H. T. Judd Driller Clarence Gorzell

Address 4527 Pasadena Ave. Sacramento 21, Calif. Address Lake City, Calif. Lic. No. 484

Location of well: NE ¼ SE ¼ Sec. 29, T. 44 N/S, R. 19 E, in Washoe County

Permit No. None Required

Water will be used for Domestic use Total depth of well 80'

Size of drilled hole 12" to 50' - 6" to 80' Weight of casing per linear foot 13 #s

Thickness of casing .188 wall Temp. of water cold

Diameter and length of casing 6" 80'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 21 ft.

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well July 18th 1966 Date of completion of well July 20th 1966

Type of well rig

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	18'	18'	Sandy loam
18'	58'	40'	Clay
58'	80'	22	Sand & gravel - light streaks of clay. (6")

Water-bearing Formation, Casing Perforations, etc.

Chief aquifer (water-bearing formation)

from 58' to 80' ft.

Other aquifers

First water at 60 feet.

Casing perforated

from 55' to 80' ft.

Size of perforations

1/8" x 4" - 8 cuts per foot

(OVER)

919

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
6" I D.			80'	12" Hole Drilled to 50' Hole Cemented to 30'

GENERAL INFORMATION—Pumping Test, or Boiling Test, Quality of Water, etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Clarence Gorgell
Well Driller

By

License No. 484

Dated Aug. 17, 1966

(Not to be filled in by Driller)

1966 AUG 19 AM 11 26