Log No. 9186
Rec. Sept 30 1966
Well No.
Permit No. 23671

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Do not fill in.

Owner Nancy Torrey & Idell Ferber Driller Clarence Gorzell

Address Cedarville, Calif. Address Lake City, Calif. Lic. No. 484

Location of well: NE 1/4 NE 1/4 Sec 29, T. 43 N/S, R. 19 E, in Washoe County

Permit No.

Water will be used for IRRIGATION Total depth of well 310'

Size of drilled hole 12 3/4" Weight of casing per linear foot ~~18.38~~ 25.16 # per foot

Thickness of casing 3/16" Temp. of water Cold

Diameter and length of casing 12 3/4" x 310'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 76'

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well August 3, 1966 Date of completion of well August 30, 1966

Type of well rig Cable Tool

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	2 1/2'	2 1/2'	Top soil
2 1/2	42	39 1/2	Gravel - Clay - cemented - very hard
42	67	25	Clay and sand - cemented
67	75	8	Rock and clay - cemented
75	82	7	Coarse sand - possible water
82	120	38	Gravel - sand - fine sand
120	155	35	Brown clay - streaks of sand stone streaks of gravel and fine sands
155	170	15	Coarse sand - sand stone streaks
170	190	20	Clay and sand - mixed - soft between streaks of sand stone
190	294	104	Clay - gravel - sand impregnated
294	305	11	Coarse gravel and sand
305	310	5	Hard - sticky clay - some sand

Water-bearing Formation, Casing Perforations, etc.

Chief aquifer (water-bearing formation)
from 294 to 305 ft.

Other aquifers 75' - 82'
82' - 120'
155' - 170'

First water at 75 feet.

Casing perforated
from 75 to 305 ft.

Size of perforations
3/8" x 4"

(OVER)

919

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
12 3/4	0	310	310	

GENERAL INFORMATION—Pumping Test, or Boiling Test, Quality of Water, etc.

Testing and Developing 18 hours -
Static water level 76 Feet
Draw down 145 Feet 460 G.P.M.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Clarence Gozell
Well Driller

By

License No. 484

Dated Sept. 28, 19 66

(Not to be filled in by Driller)