From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
2 3/4"	0	403	403	Gravel packed from bottom to 50' level, top 50 feet cemented in place.

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

Test pumped 480 GPM, from 200', clear and sand free.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Fred H. Allen Well Driller

By

License No. 40

Dated 10-4-, 1966

(Not to be filled in by Driller)

RECEIVED
OCT 13 1966
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA