

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Bureau of Land Management ADDRESS Elko District

2. LOCATION NE 1/4 SE 1/4 Sec. 32 T. 29 N. R. 56 E. Elko County  
PERMIT NO. (Bid # 1930)

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Red Sandy Clay</u>		<u>225</u>	<u>350</u>	<u>125</u>
<u>Red Sand - Water</u>		<u>350</u>	<u>380</u>	<u>30</u>
<u>Red Clay</u>		<u>380</u>	<u>385</u>	<u>5</u>
<u>(Drive casing from 350 to 385 down the sand)</u>				

8. WELL CONSTRUCTION  
Diameter hole 6 inches Total depth 385 feet  
Casing record.  
Weight per foot 18 lbs Thickness 280  
Diameter From To  
..... inches feet feet  
Surface seal: Yes  No  Type Cement  
Depth of seal 3 feet  
Gravel packed: Yes  No   
Gravel packed from..... feet to..... feet  
Perforations:  
Type perforation Factory Cut  
Size perforation 1/2 x 3/8 6 Rows  
From 375 feet to 355 feet  
From..... feet to..... feet  
From..... feet to..... feet  
From..... feet to..... feet  
From..... feet to..... feet

Date started 7-3, 1967  
Date completed 7-14, 1967

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
Static water level 350 Feet below land surface  
Flow..... G.P.M.  
Water temperature..... ° F. Quality Good

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name O.M. Gullard Drilling  
Address 6044 S Euclid, LV, Nev  
Nevada contractor's license number 4796  
Nevada driller's license number 115  
Signed O.M. Gullard Driller  
Date 7-29-67

BAILER TEST  
G.P.M. 12 Draw down 0 feet 1 hours  
G.P.M. Draw down..... feet..... hours  
G.P.M. Draw down..... feet..... hours