DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 9820
Permit No.
Basin CARD

1. OWNER John Turner ADDRESS Elko, Nevada

2. LOCATION NW ¼ NW ¼ Sec. 20 T. 34 N/S R. 55 E. Elko County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
yellow clay			14'	
sand & gravel	water	14'	22'	8'
clay & gravel		22'	52	30
clay		52	128	76
gravel		128	133	5
clay		133	153	20
gravel		153	156	3
clay		156	175	19
gravel	water	175	183	8
clay		183	189	6
gravel		189	194	5
clay		194	200	6
sand		200	218	18

Date started 10/31/67, 19
Date completed 11/9/67, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 218 feet
Casing record 8" to 60' 6" from surface to 218'
Weight per foot 17 lbs Thickness 1/4"

Diameter	From	To
8 inches	surface feet	60 feet
6 inches	surface feet	218 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐ on outside of 6"
Gravel packed from feet to feet

Perforations:
Type perforation torch cut
Size perforation 1/8 x 5" slots
From 150 feet to 215 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 28' Feet below land surface 28'
Flow 15 gpm at G.P.M. 180'
Water temperature cold° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W. H. Muth
Address P. O. Box 307 Elko, Nevada
Nevada contractor's license number 3473 A
Nevada driller's license number 211
Signed W H Muth
Date 12-6-67

USE ADDITIONAL SHEETS IF NECESSARY

5471