DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10050
Permit No.
Basin [illegible] CARD

1. OWNER CARL McAVIS ADDRESS CARSON CITY NEV

2. LOCATION ¼ ¼ Sec. 22 T. 15 N/S R. 20 E. ORMSBY County
PERMIT NO. 1150 PINON HILLS DRIVE

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SOIL	NO	0	19	19
BROKEN LIME ROCK	NO	19	23	4
BLUE CLAY	NO	23	32	9
GRAVEL	YES	32	33	1
RED CLAY	NO	33	51	18
GREY SANDY CLAY	NO	51	65	14
SAND & GRAVEL	YES	65	80	12
GREY SANDY CLAY	NO	80	85	5

Date started MAY 2, 1968
Date completed MAY 7, 1968

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 ~~Draw down~~ RAISE 2½ feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 88 feet
Casing record
Weight per foot 17 Thickness .188

Diameter	From	To
8 3/8 inches	1 ABOVE feet	89 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CEMENT GROUT
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 80 feet to 50 feet

Perforations:
Type perforation 3/32 X
Size perforation Box 3 MILL SLOT
From 50 feet to 89 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 22 ft. Feet below land surface YES
Flow G.P.M.
Water temperature 97 ° F. Quality NO TEST

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name [illegible]
Address Carson City Nevada
Nevada contractor's license number [illegible]
Nevada driller's license number [illegible]
Signed [illegible]
Date May 7, 1968

USE ADDITIONAL SHEETS IF NECESSARY

5471