CLIENT'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10089
Permit No. 51635
Basin 212

1. OWNER State of Nev. Dept of Highways ADDRESS Carson City Nevada

2. LOCATION 5½ N W ¼ SW ¼ Sec. 28 T. 19 N/S R. 57 E. Clark County
PERMIT NO. 51635

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. Mtc PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND GRAVEL - BOULDERS		0	108	108
CEMENTED CONGLOMERENT		108	230	112
" "				
WEATHER STREAKED				
CLAY AND SOME				
LOOSE GRAVEL		230	286	56
Limestone		286	297	11

Charleston Wall

Date started 5/5, 1968
Date completed 6/8, 1968

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down NONE feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 297 feet
Casing record 297
Weight per foot Thickness 3/16

Diameter	From	To
10 inches	0 feet	51 feet
6 inches	0 feet	297 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUTE
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 297 feet

Perforations:
Type perforation TOURCH CUT
Size perforation ¼ X 6 - 4 TO THE ROUND 6" APART
From 297 feet to 297 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 67 Feet below land surface 230
Flow NO G.P.M. 10 PER MIN.
Water temperature 50 ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name James A Wakeling
Address 1350 KIMAN AVE RENO
Nevada contractor's license number N. S. H. D.
Nevada driller's license number 506
Signed James A Wakeling
Date June 8, 1968

USE ADDITIONAL SHEETS IF NECESSARY

5471