DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10210
Permit No. 24254
Basin STEPTOE V.

1. OWNER Austin Flint ADDRESS Cisco, Texas

2. LOCATION NW ¼ NE ¼ Sec. 35 T. 21 N/S R. 63 E. White Pine County
PERMIT NO. 24254

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☑ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		1	3	
Brown + Clay		3	35	
Boulders		35	40	
Brown + Clay		40	50	
Brown + Sand	X	50	55	
Clay + Brown		55	70	
Brown	X	70	75	
Clay + Brown		75	95	
Sand + Brown	X	95	105	
Clay + Brown		105	120	
Brown	X	120	125	
Clay + Brown		125	135	
Sand + Brown	X	135	145	
Cemented Sand + Brown		145	153	
Sandy Clay + Brown		153	165	
Sand + Brown	X	165	175	
Sandy Clay + Brown		175	195	
Cemented Sand + Brown		195	199	
Clay + Brown		199	200	
Clay + Brown		200	220	
Sandy Clay + Brown		220	240	
Clay		240	250	
Clay + Brown		250	265	
Sand + Brown	X	265	295	
Clay		295	300	

Date started 7/18/68, 19 68
Date completed 7/1/68, 19 68

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1760	1400	80	4 hours

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 19 inches Total depth 300 feet
Casing record
Weight per foot ..... Thickness 2.19

Diameter	From	To
16 inches	0 feet	227 feet
14 inches	220 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☑ Type
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Slot no wire
Size perforation 3/16 - 12" long
From 50 feet to 295 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 44 Feet below land surface 44
Flow ..... G.P.M.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim Schooler
Address Box 833, Ely, Nev.
Nevada contractor's license number 9557
Nevada driller's license number 515
Signed Jim Schooler
Date 8-12-68

USE ADDITIONAL SHEETS IF NECESSARY

5471