DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10248
Permit No. 23242
Basin

1. OWNER David A Wills ADDRESS 1000 Vaughn Building
Dallas, Texas

2. LOCATION NW ¼ SW ¼ Sec. 13 T. 10 N/S R. 65 E. White Pine C
PERMIT NO. 23242, North Eldridge Well

3. TYPE OF WORK				4. PROPOSED USE					5. TYPE WELL	
New Well	☑	Recondition	☐	Domestic	☐	Irrigation	☐	Test	☐	Cable ☑ Rotary
Deepen	☐	Other	☐	Municipal	☐	Industrial	☐	Stock	☑	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	5	5
pea gravel soil		5	100	95
Water gravel		100	125	25
Hard rock		125	130	5

Date started Oct 20, 1966
Date completed Nov 2, 1966

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 To 42 Draw down 12 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 130 feet
Casing record 130 Feet
Weight per foot Thickness ¼

Diameter		From		To	
10	inches	0	feet	100	feet
8	inches	100	feet	130	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☐ No ☑ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Mills
Size perforation ½ x 3" long
From 115 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 115 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Eldridge
Address Ely, Nev. Spring Va.
Nevada contractor's license number
Nevada driller's license number
Signed Don Eldridge
Date

USE ADDITIONAL SHEETS IF NECESSARY