DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10274
Permit No. 25266
Basin 160

1. OWNER ~~Nye County~~ UNINCORPORATE TOWN OF PAHRUMP. ADDRESS TONAPAH

2. LOCATION N.E. ¼ S.E. ¼ Sec. 10 T. 20-S N/S R. 53 E. NYE County
PERMIT NO. ~~25266~~ 25266

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ■ Recondition ☐	Domestic ☐ Irrigation ■ Test ☐	Cable ☐ Rotary ■
Deepen ☐ Other ☐	Municipal ■ Industrial ☐ Stock ☐	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	15	15
Clay		15	28	
Conglomerate		28	34	06
Clay		34	35	
Conglomerate		35	57	
Clay		57	60	03
"		60	66	
"		66	81	
Conglomerate		81	91	
Clay		91	93	02
Cemented Gravel		93	94	01
Clay		94	98	01
"		98	99	
Sand stone		99	115	
Clay		115	152	
Sand		152	156	
Clay		156	199	
Clay stks. Lime Stone		199	234	
Hard layer Caliche		234	236	02
Clay with stks limestone		236	321	
Grey limestone		321	332	
Sand		332	333	
Lime stone or Caliche		333	340	
Sand		340	341	
Lime stone or Caliche		341	344	
Sand & stks of Limestone		344	360	
Clay		360	364	
Blue limestone		364	410	

Date started July. 13, 19 70
Date completed ____, 19 ____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	285	85	
	580	155	8 hrs

BAILER TEST

G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION

Diameter hole 16 inches Total depth 410 feet
Casing record 10 3/4" C.D.
Weight per foot ____ Thickness 3/16

Diameter	From	To
10 3/4" C.D. inches	0 feet	410 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type Cement
Depth of seal ____ feet
Gravel packed: Yes ☐ No ☐
Gravel packed from 50 feet to 410 feet

Perforations:
Type perforation Torch Cut
Size perforation ¼" X 8" X 3 Rounds
From 80 feet to 410 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL

Static water level 38 Feet below land surface
Flow ____ G.P.M.
Water temperature ____° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ken Floyd Pump Co.
Address P.O. Box 157 Pahrump.
Nevada contractor's license number 7479
Nevada driller's license number 476
Signed Kenny E. Floyd
Date 11-10-70

USE ADDITIONAL SHEETS IF NECESSARY

5471