DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10294
Permit No.
Basin. 88

1. OWNER John R. Legg ADDRESS 12250 Jeppson Ln
Reno Nevada - (P.O. Box 125 Steamboat Nev)

2. LOCATION SW ¼ SE ¼ Sec. 34 T. 18 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Large Boulders		0	68	68
Granite		68	84	16
Loose Rock		84	101	17
Granite		101	105	4
Loose Rock		105	140	35
Granite		140	170	30
Course Sand + Sm Gravel	170	170	182	12
Granite		182	185	3
Sixty ft Rock Filter				
In Bottom For Sand Protection				

Date started 9/18, 1968
Date completed 10/23, 1968

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 12 To 15 Draw down 4 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 185 feet
Casing record 8" - X 185 ft -
Weight per foot 15 Thickness 3/16"

Diameter	From	To
12 inches	0 feet	50 feet
8" inches	50 feet	185 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Torch Cut
Size perforation [redacted] - Med x 6"
From 165 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 150 Feet below land surface
Flow G.P.M.
Water temperature 50 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name J. W. Cunningham
Address Rt 1 Box 844 Reno
Nevada contractor's license number 6724
Nevada driller's license number 242
Signed J W Cunningham
Date 10/24/68

USE ADDITIONAL SHEETS IF NECESSARY

5471