DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10559
Permit No.
Basin Truckee Basin

1. OWNER Henry Kaller ADDRESS Smith Polati Inc
160 Coyote 195-E 6th Ave
Washoe City Sparks Nev

2. LOCATION ¼ ¼ Sec. T. N/S R. E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Sand		0	4	4
Decomposed Granite		4	200	196

Date started 3-15, 1968
Date completed 4-6, 1968

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down 150 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 200 feet
Casing record
Weight per foot 12.59 Thickness 188

Diameter	From	To
6 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 30 ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 30 feet to 200 feet

Perforations:
Type perforation Torch Cut
Size perforation 5/16 - 4 Rows
From 150 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 Feet below land surface 60
Flow G.P.M.
Water temperature 214 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Smith Polati Inc
Address 195-E 6th Ave Sparks
Nevada contractor's license number 6425A
Nevada driller's license number 207-208
Signed Claude Polati
Date

USE ADDITIONAL SHEETS IF NECESSARY

5471