DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10607
Permit No. 23346
Basin Pine Forest 029
31048

1. OWNER Stanley S. Moore ADDRESS 3737 N.Wilson Way; Stockten, California

2. LOCATION S ¼ W ¼ Sec. T. 44 N/S R. 31 E. Humboldt County
PERMIT NO. 23346

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy topsoil		0	6	6
Fine to coarse sand w/ rounded gravels to 3"		6	41	35
Coarse sand		41	73	32
Hard sandy yellow cly		73	88	15
Fine to coarse sand w/ semi-rounded gravels to 1"		88	90	2
Soft sandy yellow cly		90	93	3
Fine to coarse sand w/ approx. 2% silt- some gravels to 1"		93	130	37
sandy yellow clay		130	140	10
hard yellow clay		140	200	60
red sandy clay		200	220	20
fine to coarse sand w/ some gravels to 3/4"		220	240	20
hard yellow clay		240	255	15
soft sandy yellow clay		255	263	8
hard yellow clay- some gravels to 1" mixed		263	275	12
Hard yellow shale- becoming progressively harder		275	298	23

Date started 25 March, 1969, 19
Date completed 27 March, 1969, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Hole was not cased. It was felt that there was an insufficient number of aquifers to warrant casing & completion. Further drilling pending owner's decision.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 24 inches Total depth 298 feet
Casing record none
Weight per foot Thickness

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.I. McDonald & Co.
Address 1715 Trabert Way; Sparks, Nev.
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed W L McDonald
Date 15 May, 1969

USE ADDITIONAL SHEETS IF NECESSARY

5471