DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 10652
Permit No.
Basin Alaska Valley Truckee Meadows

1. OWNER W. H. Ward ADDRESS 521 Lake, Reno

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 20 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Soil | | 0 | 2 | 2 |
| Clay | | 2 | 56 | 54 |
| Broken Rock | W | 56 | 105 | 49 |
| Sand | W | 105 | 108 | 3 |
| Broken Rock | | 108 | 110 | 2 |

Date started June 27, 19 69
Date completed July 8, 19 69

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 10 Draw down 2 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 5/8 inches Total depth 110 feet
Casing record +1 - 110
Weight per foot Thickness 188

| Diameter | From | To |
|---|---|---|
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 53 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Saw slot
Size perforation ⅛ x 3
From 90 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 18 Feet below land surface
Flow G.P.M. 0
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leroy Matthews & Son
Address P.O. 7334 Reno Nev.
Nevada contractor's license number 9910
Nevada driller's license number 549
Signed Leroy Matthews
Date July 11 - 69

USE ADDITIONAL SHEETS IF NECESSARY

5471