DIVISION OF WATER RESOURCES

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10813
Permit No.
Basin Truckee Meadows

1. OWNER DOROTHY CAFFREY ADDRESS 2250 HOLCOMB LANE RENO, NEVADA

per POC investigation 12/16/08 NE

2. LOCATION NE ¼ SE ¼ Sec. 12 T. 18 N/S R. 19 E. WASHOE County

PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	3	3
CLAY, SAND + COBBLES		3	6	3
CLAY + HARD SAND		6	8	2
CLAY + COURSE GRAVEL		8	10	2
COURSE SAND + COBBLES		10	12	2
COURSE BLACK SAND + CLAY		12	20	8
BROWN CLAY + COURSE SAND		20	27	7
SAND W/ TRACE OF CLAY		27	29	2
FINE SAND + COBBLES		29	32	3
COURSE GRAVEL + SAND W/ TRACE OF CLAY		32	35	3
TAN CLAY SAND + COURSE GRAVEL		38	44	6
CLAY, SAND, + COURSE GRAVEL		44	50	6
CLAY (TAN) + SAND		50	53	3
SAND + TRACE OF CLAY		53	57	4
SAND + COBBLES		57	61	4
COURSE GRAVEL W/ TRACE CLAY		61	84	23
CLAY + SAND		84	86	2
SAND		86	90	4
COURSE SAND + GRAVEL		90	110	20
COURSE GRAVEL W/ TRACE CLAY		110	112	2
VERY COURSE GRAVEL/CLAY BALLS		112	114	2
COURSE SAND, TRACE CLAY		114	129	15

Date started JULY 16, 1969
Date completed JULY 31, 1969

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down 15' feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 130 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
10 inches	20 feet	35' 1" feet
6 inches	+1 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CEMENT GROUT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation FACTORY CUT
Size perforation 1/8" X 3"
From 108 feet to 128 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20' Feet below land surface
Flow G.P.M. 1
Water temperature COLD° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name RENO PUMP + SUPPLY
Address 1466 SO. VIRGINIA ST. RENO
Nevada contractor's license number 5301
Nevada driller's license number 285
Signed Kenneth Roman
Date 11/25/69

USE ADDITIONAL SHEETS IF NECESSARY

5471