DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10818
Permit No.
Basin Carson Valley CARD

1. OWNER Mr. John Davis ADDRESS Star Route; Minden, Nevada

2. LOCATION ¼ ¼ Sec. 26 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. Green Acres Subdivision

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loamy topsoil		0	2	2
Decomposed granite sand				
some black soil mix.	yes	2	6	4
DG sand & black clay		6	13	7
DG sand & black clay				
w/ some grvls to ½"	flows	13	15	2
Soft black clay		15	18	3
DG w/ rded. gravls				
to ½"		18	19	1
Hard & soft black cly		19	37	18
DG & ylw cly lenses		37	50	13
Hard & soft ylw cly w/				
coarse sand lenses		50	70	20
Coarse sand w/ rded				
grvls to ½"	yes	70	83	13

Date started 1 November, 1969, 19
Date completed 5 November, 1969, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:			
	10GPM @ 21'		
	15GPM @ 42'		
	20GPM @ 52'		2hrs.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10½" inches Total depth 83' feet
Casing record 0-83'
Weight per foot 12 lbs Thickness .188

Diameter		From		To	
65/8"OD	inches	0	feet	83	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Std. mix w/ 2% calcium chloride
Depth of seal 53'
Gravel packed: Yes ☒ No ☐
Gravel packed from 53 feet to 83 feet

Perforations:
Type perforation ~~-ex~~mill slot(saw cut)
Size perforation 1/8" x 3"
From 65 feet to 82 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... Feet below land surface .....
Flow 1½ G.P.M.
Water temperature norm. ° F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address 1715 Trabert Way; Sparks, Nev.
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed [signature]
Date 12 November, 1969

USE ADDITIONAL SHEETS IF NECESSARY

5471