DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10865
Permit No.
Basin Truckee Meadows

1. OWNER Joe Capurro ADDRESS Box # 412 Sparks Nev 89431

2. LOCATION NW ¼ SE ¼ Sec. 21 T. 20 N/S R. 20 E. M.D.B.+M. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☒

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Grey Lava		64	82	18
Cemented Gravel		82	95	13

This Well drilled by H+H in April of 1966. Well left open. Filled in with rock + wood to 39 ft. Drilled out fill. found bottom of well at 64. Bailed 4 GPM at 80 ft. Drilled to 95 ft. Making a good well.

Spanish Springs
Sec 21
T 20 N SWSE
R 20 E SESW
65 ss - Capurro
Pyramid Lake Highway

Date started 1-1, 19 70
Date completed 1-15, 19 70

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 55 Draw down 9 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 95 feet
Casing record Added 16 ft
Weight per foot 12.89 Thickness 188

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Mud
Depth of seal ? feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 Feet below land surface
Flow None G.P.M.
Water temperature 70 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Smith - Pulati Inc.
Address 295 - 16th Ave Sparks
Nevada contractor's license number 6425A
Nevada driller's license number 207 + 208
Signed Claude Pulati
Date 1-14-70

USE ADDITIONAL SHEETS IF NECESSARY

5471