DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10880
Permit No. 25600
Basin Truckee Meadows

1. OWNER Louis Damonti ADDRESS 12945 Old Virginia Rd Reno Nevada

2. LOCATION SE ¼ NE ¼ Sec. 20 T. 18 N/S R. 20 E. Washoe County
13201 S. Virginia St. APN 049-230-02
PERMIT NO. Applied For 25600 N 39.413283 W 119.756169 NAD27

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rocky Top Soil		0	2	2
Rocky Clay Hard pan		2	14	
Sandy Clay		14	44	30
Coarse Brown Sand	W	44	70	26
Fine Brown Sand		70	95	25
Plugged water NOT 62565				

Date started Dec 2, 1969
Date completed Jan 7, 1970

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
15 HP Sub -	175	10'	6 Hours

BAILER TEST
G.P.M. 70 Draw down 1 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 95 feet
Casing record 10" X 95'
Weight per foot Thickness 10 gauge

Diameter	From	To
16 inches	0 feet	45 feet
10 inches	45 feet	95 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 44 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 44 feet to 62 feet

Perforations:
Type perforation Factory
Size perforation 3-1/32
From 45 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 Feet below land surface 30'
Flow G.P.M.
Water temperature 62 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & B Contractors
Address RT-1 Box 1-Thiske Sparks
Nevada contractor's license number 6538
Nevada driller's license number 287
Signed M. Artlip
Date Jan 8 1970

USE ADDITIONAL SHEETS IF NECESSARY

5471