DIVISION OF WATER RESOURCES

#6 Copy sent to CC 3-2-70

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10916
Permit No.
Basin

1. OWNER Hollis Harris ADDRESS N.E. CORNER

2. LOCATION S.W. ¼ S.E. ¼ Sec. 11 T. 21 N/S R. 53 E. NYE County
PERMIT NO. 24505

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	6	6
Caliche w Silts of Clay		6	33	27
Hard Caliche	✓	33	40	7
Caliche w Silts of Clay		40	77	37
Clay w Silts of Caliche		77	113	36
Hard Caliche -		113	114	01
Caliche Hard & Soft		114	122	08
Clay		122	128	06
Hard Caliche		128	136	08
Loose Soft Caliche		136	148	08
Clay		148	159	11
Caliche Silts Hard & Soft		159	171	12
Clay		171	174	03
Caliche Hard		174	182	08
Caliche Hard & Soft Silts		182	197	15
Clay with Silts of Caliche		197	227	30
Clay		227	234	07
Caliche		234	236	02
Clay		236	242	06
Clay w/ Silts of Caliche		242	263	21
Caliche -		263	272	09
"		272	287	15
Clay w Silts of Gravel		287	313	26
Caliche		313	316	03
Clay - w Silts of Caliche		316	347	31
" " "		347	377	30
" " " "		377	409	22

Date started 5-25-69, 19
Date completed 10-20, 19 70

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
480	G.P.M. @	160	Left.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 17 inches Total depth 409 feet
Casing record 12 3/4
Weight per foot 28 LB Thickness 3-16

Diameter	From	To
12 3/4 inches	0 feet	409 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch Cut
Size perforation 3/8" x 4 Rounds 8" Low
From 40' feet to 409 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 21 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ron Floyd Pump Co.
Address P.O. Box 150 Pahrump
Nevada contractor's license number 7479
Nevada driller's license number 476
Signed Ronald E. Floyd
Date 2-20-70

USE ADDITIONAL SHEETS IF NECESSARY

5471