DIVISION OF WATER RESOURCES

#3

Copy sent to CC 3-2-70

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10919
Permit No.
Basin

1. OWNER Hollis Harris ADDRESS Pahrump Nevada.

2. LOCATION N.E. CORNER N.E. ¼ S.E. ¼ Sec. 11 T. 21 N/S R. 53 E. NYE County
PERMIT NO. 24502

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Soft Clay		2	12	10
Caliche		12	14	02
Clay		14	18	4
Hard Caliche		18	28	10
Clay		28	33	05
Caliche	✓	33	38	05
Clay		38	45	07
Caliche	✓	45	48	03
Hard Caliche	✓	48	60	12
Caliche w stks of clay		60	70	10
Caliche w clay stks		70	77	07
Clay		77	93	16
Hard Caliche	✓	93	94	01
Brn Clay		94	100	06

Date started 5-25- , 1969
Date completed 5-28 , 1969

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
No Record available.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 17 inches Total depth 100 feet
Casing record —
Weight per foot — Thickness —

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation —
Size perforation —
From — feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ron Floyd Pump Co
Address P.O. Box 157 Pahrump.
Nevada contractor's license number 7479
Nevada driller's license number 476
Signed Kenny E. Floyd
Date 2-22-70.

USE ADDITIONAL SHEETS IF NECESSARY

5471