COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100043
Permit No.
Basin 105

NOTICE OF INTENT NO. 58205

1. OWNER TONY SEAWARD
MAILING ADDRESS P.O. Box 642
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1877 BORDA
GARDNERVILLE, NV 89410

2. LOCATION NE ¼ SW ¼ Sec 36 T 13 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1320-36-002-054 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| OLD 6 5/8 WELL | | +2 | 250 | 252 |
| GRAY CLAY | | 250 | 315 | 65 |
| SILTY SANDS | | | | |
| GRAY GUMMY CLAY | | 315 | 411 | 96 |
| SMALL SAND AREAS | | | | |
| SMALL GRAY SANDS | | | | |
| CLAY SEAMS | XX | 411 | 450 | 39 |

GPS INFO:

Date started 6/12, 20 06
Date completed 6/19, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 85 | 3 HRS |

8. WELL CONSTRUCTION
Depth Drilled 450 ~~205~~ Feet Depth Cased 450 ~~220~~ Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 6 1/8 Inches | 250 Feet | ~~455~~ 450 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | +2 | 250 |
| 5" | 10.46 | .188 | 235 | ~~455~~ 450 |

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3X3/32
From 235 feet to 455 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal N/A ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 235 feet below land surface
Artesian flow G.P.M 20 P.S.I
Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 6/24/06