



STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 100059
Permit No. _____
Basin 16

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56640

1. OWNE Bob Hendrix
MAILING ADDRESS 2650 Harvey Ln Fallon, NV 89406
Fallon, NV 89406

ADDRESS AT WELL LOCATION 2158 Reese Way
Fallon, NV 89406

2. LOCATION SE 1/4 SW 1/4 Sec 15 T 19 R 28
PERMIT NO Parcel No. 00808129

Latitude 39.50551 Longitude -118.8299 WGS 84
Subdivision Name _____ County Churchill

3. WORK PERFORMED
New Well

4. PROPOSED USE
Domestic

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8	8
Brown Clay		8	24	16
Brown Sand		24	42	18
Black Clay		42	53	11
Black Sand		53	69	16
Brown Clay		69	74	5
Brown Sand	X	74	80	6

8. WELL CONSTRUCTION

Depth Drilled 80 Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.5 Inches	0 Feet	50 Feet
10 Inches	50 Feet	80 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
6.625	12.92	6.625	0	20
6	3.85	0.258	20	80

Perforations:

Type perforation Saw Cut
Size perforation 0.125
From 76 feet to 80 feet

Surface Seal Yes No

Seal Type:
Concrete Grout

Depth of Seal 50

Placement Method: Pumped

Gravel Packed: Yes No

From 50 feet to 80 Feet

9. WATER LEVEL

Static Water Level 10 feet below land surfac
Artesian Flow 15 G.P.M. P.S.I.
Water temperature ° F Qualit UNKNOWN

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contracto

Address 403 McLean Road
Fallon, NV 89407

Contracto
Nevada contractor's license number 29064
issued by the State Contractor's

Nevada driller's license number issued by the 2307
Division of Water Resource, the on-site driller

Signe *[Signature]*
By driller performing the actual drilling on site or contract

Date 5/30/2006

Date started 5/24/2006

Date completed 5/24/2006

7. WELL TEST DATA

TEST METHOD

Comments GPM Drawdown Time (Hours)

Comments	GPM	Drawdown	Time (Hours)

STATE ENGINEERS OF NEVADA
2006 JUN -5 PM 2:40

RECEIVED