WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100061
Permit No.
Basin 179

NOTICE OF INTENT NO. 51409

1. OWNER Steve Robinson
MAILING ADDRESS P.O. Box 151464
Ely, Nevada 89315
ADDRESS AT WELL LOCATION 950 E. 807 S. Cave Valley Road

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 14 N/S R. 64 E. White Pine County
PERMIT NO. Parcel 2 (Issued by Water Resources) APN 012-790-07 (Parcel No.) Ward Mountain Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil & Boulders		0	3	3
Sand & Gravel		3	20	17
Clay & Small Gravel		20	30	10
Cemented Sand & Gravel		30	75	45
Clay & Small Gravel		75	85	10
Brown Clay		85	95	10
Sand		95	105	10
Cemented Sand & Gravel		105	135	30
White Clay		135	140	5
Clay with Water Bearing		140		
Sand Stringers	X		145	5
White Clay & Small Gravel		145	182	37
Water Bearing Sand &		182		
Gravel	X		185	3
White Clay		185	200	15

Date started May 8, 2006
Date completed May 12, 2006

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	58	4

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	200

Perforations:
Type perforation Factory
Size perforation 1/8" X 2½" 6 Rows
From 80 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 Feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 142 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rick Lewis By Jerald D. Christiansen
By driller performing actual drilling on site or contractor
Date May 26, 2006

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627