

Well # 2

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 100063
Permit No.
Basin. 0.92A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52989

1. OWNER Yomba Development Co ADDRESS AT WELL LOCATION
MAILING ADDRESS 7507 Vista View Dr 11200 Yomba Ln.
Reno NV 89506 Reno NV 89506
2. LOCATION SE 1/4 SE 1/4 Sec. 25 T 21 R 18 E Washoe County
PERMIT NO. 086-360-27 Silver Lakes Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Sand		3	5	2
Sandy Clay		5	17	12
Clay		17	21	4
Clay & Sand layers		21	85	64
Sand		85	125	40
Clay & Sand layers		125	162	37
Sand		162	185	23
Clay		185	220	35
Sand (Course)		220	244	24

GPS
N 39. 65186
W 119. 91504
NAD 83

8. WELL CONSTRUCTION
Depth Drilled 244 Feet Depth Cased 240 Feet
HOLE DIAMETER (BIT SIZE)
From 11 Inches To 244 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>21</u>	<u>240</u>

Perforations:
Type perforation Saw Slot
Size perforation .188
From 160 feet to 180 feet
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 244 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow N/A P.M. P.S.I.
Water temperature °F N/A Quantity

Date started 5/15, 2006
Date completed 5/22, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>90</u>	<u>235</u>	<u>4</u>

88:01:11 6-1100-9907

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Oleynski Drilling & Pump Contractor
Address 15045 Red Rock Rd Contractor
Reno NV 89506
Nevada contractor's license number 50343 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed John F. Oleynski
By driller performing actual drilling on site or contractor
Date 5/22/06