


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 100181

Permit No. _____

Basin 162



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30140

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER LYLE HELMICK
 MAILING ADDRESS 781 CARBERRY
PAHRUMP, NV

ADDRESS AT WELL LOCATION 781 CARBERRY

2. LOCATION NW 1/4 SE 1/4 Sec. 3 T 21S
 PERMIT NO. 44-231-03

N/S R 53E E NYE County

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED
 New Well
 Deepen
 Replace
 Abandon
 Recondition
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Air
 Rotary
 Other
 RVC

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------|--------------|------|-----|------------|
| CLAY | | 140 | 145 | 5 |
| CALICHE | WB | 145 | 153 | 8 |
| CLAY | | 153 | 170 | 17 |
| CALICHE | WB | 170 | 190 | 20 |
| CLAY | | 190 | 225 | 35 |
| CALICHE | WB | 225 | 234 | 9 |
| CLAY | | 234 | 240 | 6 |

8. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|-------------------|------|-----|
| EXISTING 8 Inches | 0 | 140 |
| 7 7/8 Inches | 140 | 240 |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 4.5 | 2.36 | .248 | 0 | 240 |

Perforations:

Type perforation SAWCUT

Size perforation 1/8 X 3

| From | To |
|----------|----------|
| 100 feet | 160 feet |
| 180 feet | 200 feet |
| 220 feet | 240 feet |

Surface Seal: Yes No
 Depth of Seal EXISTING
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
 Contractor
 Address 1220 E MANSE RD
 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 7/14/2006

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |

Date started 7/13/2006 19
 Date completed 7/13/2006 19

DCNR/DWR
 RECEIVED
 JUL 18 2006

LAS VEGAS OFFICE