WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100200
Permit No. 21017
Basin 212

NOTICE OF INTENT NO. 29791

1. OWNER Las Vegas Valley Water
MAILING ADDRESS 101 South Valley View Blvd. Las Vegas NV. 89153
ADDRESS AT WELL LOCATION 5925 W. Smoke Ranch rd. Las Vegas NV.

2. LOCATION NW ¼ NW ¼ Sec. 24 T. 20 N/S R. 60 E. Clark County
PERMIT NO. 21017 (Issued by Water Resources) | 138-24-101-002 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cleaned well by wire line brushing with Hypochlorite mix from 200' to 860'				
Cleaned out bottom of well approx. 25' of sand + rust				

DCNR/DWR RECEIVED JUL 20 2006 LAS VEGAS OFFICE

Date started 10 April, 2006
Date completed 7 May, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"				

Perforations:
Type perforation
Size perforation
From 200 feet to 860 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 185' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Christensen Company (Contractor)
Address P.O. Box 1249 (Contractor)
Barstow CA 92312
Nevada contractor's license number issued by the State Contractor's Board 0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660-T1
Signed Marty Garrison (By driller performing actual drilling on site or contractor)
Date 14 June 2006

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627