


COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT



OFFICE USE ONLY
 Log No. 100368
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30041
3698 S. LAS VEGAS BLVD.

1. OWNER 3700 ASSOCIATES LLC
 MAILING ADDRESS 667 MADISON AVE
NEW YORK, NY 10021-8029
 ADDRESS AT WELL LOCATION LAS VEGAS, NV

2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec 20 T 21 S R 61 E CLARK County
 PERMIT NO. DW1220 162-20-603-007
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE DEWATER
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
6-Dewatering wells				
Asphalt		0'	3"	
Brown aluvium		3"	8'	7'-9"
Caliche		8'	14'	6'
Brown silt		14'	17'	3'
Brown silty clay		17'	21'	4'
White clay		21'	26'	5'
Caliche		26'	31'	5'
Red clay		31'	33'	2'
Brown clay		33'	38'	5'
White silty clay		38'	48'	10'
Brown clay small rock		48'	51'	3'
Caliche		51'	55'	4'
Red clay		55'	63'	8'
White clay		63'	74'	12'
DCNR/DWR RECEIVED				
<u>JUL 27 2006</u>				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION
 Depth Drilled 74 Feet Depth Cased 74 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
24" Inches _____ 0 Feet _____ 74 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

 Perforations:
 Type perforation Machine
 Size perforation .25"x2.5x3 rows @13
 From _____ 35 feet to _____ 74 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ 0 feet to _____ 74 feet

Date started 6/21, 20 06
 Date completed 7/6, 20 06

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Draw Down (Feet Below Static)		Time (Hours)
G.P.M.			

9. WATER LEVEL
 Static water level _____ 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ALLEN DRILLING INC.
 (CONTRACTOR)
 Address 4015 WEST TOMPKINS AVE.
 (CONTRACTOR)
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231
 Signed Vista Allen
 By driller performing actual drilling on site or contractor
 Date 7/18/06