STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 100414
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28814

1. OWNER: Ken Hilliard - 7-Eleven Inc.
MAILING ADDRESS: PO Box 711
Dallas, Texas 75221

ADDRESS AT WELL LOCATION: (2 Wells) 600 N. Las Vegas Blvd
Las Vegas, NV
Subdivision Name: County:

2. LOCATION SE ¼ SE ¼ Sec 27 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-27-805-002
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E ☐ NAD 27
N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy w/ interbeded caliche		0	14	14
Sandy silt w/ caliche		14	21	7
Poorly graded sand	19	21	30	9

DCNR/DWR
RECEIVED
AUG 17 2006
LAS VEGAS OFFICE

Date started: 7/11/ , 20 06
Date completed: 7/11/ , 20 06

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.5	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 40 PVC	0	15

Perforations:
Type of perforation: Factory Slotted
Size of perforation: 0.02
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	0 to 10		☒ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 13 to 30 ☐ Pumped ☒ Poured
Type: #3 Monterey
Bentonite Chips: ☒ Yes ☐ No 10 to 13 ☐ Pumped ☒ Poured
Type: Medium Chips

7. Water Level
Static water level: 19 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: WDC Exploration & Wells (Contractor)
Address: 570 Corinthian Way (Contractor)
N. Las Vegas, NV
Nevada contractor's license number issued by the *State Contractor's Board*: 0012852
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~: 2057
Signed: (driller performing actual drilling on site or contractor)
Date: 8/2/2006

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY