WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100468
Permit No.
Basin Ø68

NOTICE OF INTENT NO. 57396

1. OWNER Michael Simeone
MAILING ADDRESS 16730 Mt. Rose Hw
Reno, NV 89511

ADDRESS AT WELL LOCATION 16730 Mt. Rose Hwy

2. LOCATION NW 1/4 NW 1/4 Sec. 3 T 17N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources | 047-162-17 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
On this date, we abandoned a 6" x 56' deep well.				
We perforated from 45' to surface. We then pumped				
18 sacks of neat cement mixed 5.2 gal/sack using				
tremie and pumped from the bottom to the top. We				
cut the casing off 2' below grade.				
Washoe Co. Permit #WL060063				

Date started 5/24/2006 , 19__
Date completed 5/24/2006 , 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 56 Feet Depth Cased 56 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	56

Perforations:
Type perforation Mill Knife
Size perforation Puncture
From 45 feet to surface feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. **WATER LEVEL**
Static water level 28 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2299
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 5/25/2006

USE ADDITIONAL SHEETS IF NECESSARY