WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100485
Permit No.
Basin 044

NOTICE OF INTENT NO. 50558

1. OWNER Queenstake Resources USA - Jerritt Canyon
MAILING ADDRESS HC-31 Box 78
ELKO, NV. 89801

ADDRESS AT WELL LOCATION Queenstake-Jerritt Canyon
HC-31 Box 78 ELKO, NV. 89801
Jerritt Canyon Mine

2. LOCATION SW ¼ NW ¼ Sec. 17 T 40 ☒ S R 54 ☐ ELKO County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Set Rig over JW 12 pilot				
Run drill pipe to 47'				
cleaned out Blockage to 60'				
enter Hole Down to 1435' and				
cleaned.				
mix & pump Super Plug Down				
drill pipe - 1435' to Surface				
used 58 - 50 Lb. Bags of plug				
Pumped in Lifts - 8 Bags to 200 Gals.				
Clean out Top 30' of Hole and				
placed Neat Cement - 6 Bags				
Pull out Surface Casing.				

Date started Drilled - Spring of 2003, 20
Date completed Abandon - 5-11-, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1435' Feet Depth Cased 20' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8"	Inches	0'	Feet	20'	Feet
5 3/4"	Inches	20'	Feet	800'	Feet
5 1/2"	Inches	800'	Feet	1435'	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Hole was never cased.				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 600' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ward Weaver
Contractor
Address 2305 Last Chance Rd.
Contractor
ELKO, NV. 89801
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver
By driller performing actual drilling on site or contractor
Date May 11th 2006

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627