WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100488
Permit No.
Basin 087

NOTICE OF INTENT NO. 57399

1. OWNER Sierra Signature Homes LLC
MAILING ADDRESS 50 Continental Dr.
Reno, NV 89509

ADDRESS AT WELL LOCATION 35 Clifford Dr.

2. LOCATION NW 1/4 SW 1/4 Sec. 23 T 20N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources
082-451-05 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
We abandoned this well by perforating "very thin" casing from 37' to approximately 7'. The ID was about 5 5/8". The perforations became "rips" as the blade wouldn't retract due to the casing being so thin. The top 7' was about .277 and we were unable to perforate. We then pumped 3.5 yards of neat cement mixed 5.2 gal/sack using tremie pipe from the bottom to the top. We cut the top 2' off of the well.				
Washoe Co. Permit #WL060069				

Date started 5/16/2006 , 19__
Date completed 5/17/2006 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 37 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.277	0	7
5.75		Thin	7	37

Perforations:
Type perforation Mills Knife
Size perforation Puncture, rip
From 37 feet to 7 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 6' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 5/18/2006

USE ADDITIONAL SHEETS IF NECESSARY