


COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 100518  
 Permit No. \_\_\_\_\_  
 Basin 212  


PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30321  
3141 S. LAS VEGAS BLVD.

1. OWNER WYNN LAS VEGAS LLC  
 MAILING ADDRESS 3131 LAS VEGAS BLVD. S  
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION 3141 S. LAS VEGAS BLVD.  
LAS VEGAS, NV

2. LOCATION SE 1/4 SW 1/4 Sec 09 T 21 S R 61 E CLARK County  
 PERMIT NO. 162-09-410-001

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>5-Monitor wells</b>				
Asphalt & type II		0	2	2'
Silt		2	6	4
Brown alluvium & rock		6	13	7
Tan alluvium & rock		13	16	3
White alluvium & rock		16	19	3
Caliche		19	25	6
Caliche	xx	25	35	10
Wells are temporary well to be plugged within 9 months.				
DCNR/DWR RECEIVED				
AUG 17 2006				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 35 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 35 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	pvc	sch40	0	35


 Perforations:  
 Type perforation Saw cut  
 Size perforation 1/8x6" 4 around each foot  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet 35 feet

Date started 8/12, 20 06  
 Date completed 8/12, 20 06

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level 25 feet below land surface  
 Artesian flow no G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC  
 (CONTRACTOR)  
 Address 4015 West Tompkins Ave.  
 (CONTRACTOR)  
Las Vegas, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161  
 Signed   
 By driller performing actual drilling on site or contractor  
 Date 8/15/06