


COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 100522  
 Permit No. \_\_\_\_\_  
 Basin 212



PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30321

1. OWNER WYNN LAS VEGAS LLC  
 MAILING ADDRESS 3131 LAS VEGAS BLVD. S  
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION 3141 S. LAS VEGAS BLVD.  
LAS VEGAS, NV

2. LOCATION SE  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec 09 T 21 S R 61 E CLARK County  
 PERMIT NO. 162-09-410-001

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>5-Monitor wells</b>				
Asphalt & type II		0	2	2'
Silt		2	6	4
Brown alluvium & rock		6	13	7
Tan alluvium & rock		13	16	3
White alluvium & rock		16	19	3
Caliche		19	25	6
Caliche	xx	25	35	10
Wells are temporary well to be plugged within 9 months.				
<b>DOWN/DWR RECEIVED</b>				

8. WELL CONSTRUCTION

Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches \_\_\_\_\_ 0 Feet \_\_\_\_\_ 35 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	pvc	sch40	0	35

Perforations:  
 Type perforation Saw cut  
 Size perforation 1/8x6" 4 around each foot  
 From \_\_\_\_\_ 30 feet to \_\_\_\_\_ 35 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ 0 feet to \_\_\_\_\_ 35 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ 25 feet below land surface  
 Artesian flow \_\_\_\_\_ no G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC  
 (CONTRACTOR)  
 Address 4015 West Tompkins Ave.  
 (CONTRACTOR)  
Las Vegas, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8/15/06

Date started 8/12, 20 06  
 Date completed 8/12, 20 06

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	