WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100558
Permit No.
Basin 175

NOTICE OF INTENT NO. 55282

OWNER WINN EXPLORATION
MAILING ADDRESS 800 N SHORLINE BLVD
19th FLOOR N TOWER, CORPUS Christi TX 78401

ADDRESS AT WELL LOCATION

2. LOCATION NW 1/4 SW 1/4 Sec. 24 T 20N N/S R 58E E WHITE PINE County
PERMIT NO. OG-232 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE OIL WELL CONST
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other X

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	140	140
CEMENTED GRAVEL		140	145	5
CLAY		145	240	95
SANDSTONE		240	258	18
SAND & GRAVEL	X	258	264	6
CLAY		264	307	43
SAND & GRAVEL	X	307	310	3
CLAY		310	361	51
SAND & GRAVEL		361	380	19

plugged by well log 110792

Date started 5/12/06, 19__
Date completed 5/15/06, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	80	~~[illegible]~~ 100	2.5

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	380	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	20
6		SDR-21	20	380

Perforations:
Type perforation SCREEN
Size perforation .030
From 260 feet to 280 feet
From 360 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No BENTONITE 20-54
From 54 feet to 380 feet

9. WATER LEVEL
Static water level 124 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. DBA FERTIG DRILL.
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6-21-06

USE ADDITIONAL SHEETS IF NECESSARY