WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100559
Permit No.
Basin Ø43

NOTICE OF INTENT NO. 55284

1. OWNER DAVID CORNMESSER
MAILING ADDRESS BOX 1
DEETH, NV 89823

ADDRESS AT WELL LOCATION STAR VALLEY ROAD

2. LOCATION PORTION 1/4 1/4 Sec. 35 T 37N N/S R 60 E ELKO County
PERMIT NO. Issued by Water Resources
007-560-031 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COBBLED BOULDERS		0	65	65
CALICHE CLAY		65	179	114
HARD ROCK		179	196	17
SOFT BROWN CLAY		196	198	2
HARD ROCK		198	226	28
SOFT SAND & GRAVEL	X	226	234	8
HARD ROCK		234	280	46

Date started 5/10/06 , 19__
Date completed 5/15/06 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	10		6.5

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	280	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	20
6		SDR-21	20	280

Perforations:
Type perforation SCREEN
Size perforation .030
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No BENTONITE 19-54
From 54 feet to 280 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG DBA FERTIG DRILLING
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed Sharel C. Fertig
By driller performing actual drilling on-site or contractor
Date 6-21-06

USE ADDITIONAL SHEETS IF NECESSARY