WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100563
Permit No.
Basin 045

NOTICE OF INTENT NO. 55283

1. OWNER JIM PESKE
MAILING ADDRESS P.O. BOX 8048
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION LAMOILLE
SUNSHINE LANE

2. LOCATION E1/2 **1/4** SE **1/4 Sec.** 13 **T** 33N **N/S R** 57 **E** ELKO **County**
PERMIT NO. (Issued by Water Resources) **006-520-019** (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Reconditioning
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	5	5
SANDSTONE		5	74	69
SAND & GRAVEL	X	74	78	4
CLAY		78	91	13
SAND & GRAVEL	X	91	92	1
CLAY		92	106	14
SAND & GRAVEL	X	106	120	14

Date started 6/09/06 , 19__
Date completed 6/14/06 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	45		4.5

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10	Inches	0 Feet	120 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	19
6		SDR-21	19	120

Perforations:
Type perforation SCREEN
Size perforation .030
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Bentonite 20-55
Gravel Packed: [X] Yes [ ] No
From 55 feet to 120 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR.,DBA FERTIG DRILL. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0319004
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed Sharel C. Fertig (By driller performing actual drilling on-site or contractor)
Date 6-21-06

USE ADDITIONAL SHEETS IF NECESSARY