WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100570
Permit No.
Basin 106

NOTICE OF INTENT NO. 57415

1. OWNER Matthew Ogan
MAILING ADDRESS P.O. Box 2882
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 4020 Gray Hills Rd.
Topaz

2. LOCATION SW 1/4 SW 1/4 Sec. 11 T 10N N/S R 22E E Douglas County
PERMIT NO. (Issued by Water Resources) | Parcel No. 1022-11-002-036 | Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [X] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We removed a 6" liner cleaned and reamed hole to 240' and installed a new 6" liner from 130' to 240' the 4" liner was removed by others.				

Date started 5/24/2006, 19__
Date completed 5/25/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	130	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8/58	16.94	.188	+2	190
6/58	12.92	.188	130	240

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 190 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 6/2/2006

USE ADDITIONAL SHEETS IF NECESSARY