WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100573
Permit No.
Basin 066

NOTICE OF INTENT NO. 57022

1. OWNER Newmont mining Corp
MAILING ADDRESS P.O. Box 69 Golconda NV, 89414
ADDRESS AT WELL LOCATION Twin Creeks mine - Environmental Dept. 30 miles north of Golconda, NV

2. LOCATION SW ¼ SW ¼ Sec. 28 T. 39 N/S R. 43 E Humboldt County
PERMIT NO. MO-1408 (Issued by Water Resources) NW (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. MW28-1 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drill to 140' Looking for H2O along the way - first encounter @ 60' Apx 1/or 2 gpm. get to 140' H2O @ 2½ to 3 gpm				
Set PVC to -140 up to +3' Screen 140 to 110.				
Place #8 Sand in hole from 140 up to 102				
Place 3/8 Hole plug from 102 up to 50'				
Pour in Cement from top fill up ~~to~~ top 50' of hole				
Develope well - Pour Cement Pad and weld on monument				

Date started 6/13, 2006
Date completed 6/15, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2-3	—	—

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	20 Feet	140 Feet
14 3/4 Inches	0 Feet	20 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2	Sch80	1/4	+3	140

Perforations:
Type perforation Slot
Size perforation .020
From 140 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140 feet to 102 feet

9. WATER LEVEL
Static water level 111 feet below land surface
Artesian flow no G.P.M. — P.S.I.
Water temperature — °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co (Contractor)
Address P.O. Box 2748 (Contractor)
EKO NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
Signed D. Skl (By driller performing actual drilling on site or contractor)
Date 6/15/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627