

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29063

1. OWNER Mike - SAB, A Nevada LLC ADDRESS AT WELL LOCATION 806 Bruner ST
 MAILING ADDRESS Woodland Hills, Ca. 91364 Enterprise, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 4 T 235 N/S R 601 E Clark County
 PERMIT NO. 59913 19104402003 NA

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other COMMERCIAL

4. PROPOSED USE Commercial
 Domestic Irrigation Test Monitor Stock Municipal/Industrial

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Perforate Well</u>		<u>715</u>	<u>240</u>	
<u>Mills Knife perforate</u> <u>4 cuts per ft</u> <u>3/8" width</u>				
<u>Displaced new</u> <u>Cement from</u> <u>Bottom to surface</u> <u>12 yds neat Cement</u> <u>of Pumped.</u>				
<u>Plugging of log</u> <u>32986</u>				

8. WELL CONSTRUCTION
 Depth Drilled 720 Feet Depth Cased 720 + 1 Feet

HOLE DIAMETER (BIT SIZE)
9 7/8 Inches From 0 Feet To 720 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>14.5</u>	<u>.156</u>	<u>+1</u>	<u>720</u>

Perforations:
 Type perforation Mills Knife 3/8 x 2"
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 720 feet

9. WATER LEVEL
 Static water level 293 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6/29/06 20 _____
 Date completed 7/1/06 20 _____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thompson Drilling Contractor
 Address 4930 Utah Ave
Las Vegas, NV 89104 Contractor
 Nevada contractor's license number 4286 A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2120TI
 Division of Water Resources, the on-site driller
 Signed George A. Co
 By driller performing actual drilling on site or contractor
 Date 8/30/06