37° 49.7 N 118° 06.260 W 5

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100664
Permit No.
Basin 117

NOTICE OF INTENT NO. 25467

1. OWNER Nevada Land Ranches
MAILING ADDRESS
ADDRESS AT WELL LOCATION Water Mountain Ranch

2. LOCATION SE ¼ SW ¼ Sec. 28 T. 1 N/S R. 35 E. Esmeralda County
PERMIT NO. (Issued by Water Resources) 007-081-03 (Parcel No.) Mountain Water Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		1	7	
Boulder		7	17	
Sand Gravel		17	37	
Boulder		37	65	
Sand Cobbles		65	146	
Boulder		146	167	
Sand, Cobbles		167	340	
(Some Boulders)				

DCNR/DWR
RECEIVED
AUG 24 2006
LAS VEGAS OFFICE

Date started 7/14/06, 20
Date completed 7/17/06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	1 Feet	106 Feet
8 3/4	Inches	106 Feet	340 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	340

Perforations:
Type perforation 3 Mill Perf
Size perforation 3/16 x 4 x 6
From 280 feet to 300 feet
From 320 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100+
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout Bentonite
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 340 feet

9. WATER LEVEL
Static water level 116 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Driller (Contractor)
Address P.O. Box 588 (Contractor)
Sp NV 89408
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 18716
Signed (By driller performing actual drilling on site or contractor)
Date 8/1/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627