

37 25.472 N 117 58.582 W

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 100670
Permit No. _____
Basin. 117

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25458

1. OWNER Jim Wallace ADDRESS AT WELL LOCATION HC 7200 1500' / Wallace Rd
MAILING ADDRESS Dyer 89010
2. LOCATION SE 1/4 SE 1/4 Sec. 16 T. 4N S. 30 E. Comanche County
PERMIT NO. 007-740-07 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		1	12	
Gravel		12	26	
Sand, Gravel		26	93	
Clay, Sand		93	114	
Gravel		114	173	
Clay, Small		173	216	
Gravel Layer		216	240	
Gravel/Cobble		240	263	
Gravel, Clay		263	290	
Clay		290	299	

8. WELL CONSTRUCTION
Depth Drilled 299 Feet Depth Cased 300 Feet
HOLE DIAMETER (BIT SIZE)
From 1 Feet To 299 Feet
10 5/8 Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	20
6 5/8	14	2.14	20	299

Perforations:
Type perforation Machine
Size perforation 1/8 x 7 x 5 # round part
From 220 feet to 240 feet
From 260 feet to 299 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 60 Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From 60 feet to 299 feet

9. WATER LEVEL
Static water level 117 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 62 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jim Diller Contractor
Address 20599 S.S. NV 89428 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed Jim Diller
By driller performing actual drilling on site or contractor
Date 9/2/06

Date started 8/29/06, 20____
Date completed 8/30/06, 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>1/2</u>	<u>2 1/2</u>	<u>1 hr</u>