WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100729
Permit No.
Basin 162

NOTICE OF INTENT NO. 30177A

1. OWNER FRED DUVALL
MAILING ADDRESS 1441 W CALVADA
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1441 W CALVADA

2. LOCATION SW 1/4 NW 1/4 Sec. 29 T 20S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 40-251-09 (Parcel No.) CALVADA VALLEY UNIT 5 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WHEN TRYING TO DEEPEN				
WELL HIT STEEL @ 135'.				
RIPED CASING AND				
CLEARED GRAVEL PACK				
FROM WELL TO 135'.				
PUMP BEONTONITE GROUT				
FROM 135' TO 40'.				
CONCRETE GROUT PLUG				
FROM 40' TO SURFACE.				

DCNR/DWR
RECEIVED
SEP 13 2006
LAS VEGAS OFFICE

Date started 9/7/2006, 19__
Date completed 9/7/2006, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
EXISTING	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXISTING				

Perforations:
Type perforation AIR PERFONDATION
Size perforation
From 50 feet to 135 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 135
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout
☒ Bentonite

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed ____ (By driller performing actual drilling on-site or contractor)
Date 9/12/2006

USE ADDITIONAL SHEETS IF NECESSARY